



425 Hanley Industrial Court, St. Louis, MO 63144
Phone: (314) 644-4300, Fax: (314) 644-5332
www.indeeco.com

INSTALLATION INSTRUCTIONS of the «UCI» Relay Kit

THE INSTALLATION MUST BE EXECUTED BY A QUALIFIED TECHNICIAN



CAUTION
DISCONNECT ALL POWER SUPPLIES
BEFORE WORKING ON ANY CIRCUIT.

INSTALLATION :

- 1) Remove access control box cover of the heater.
- 2) Position the relay in the control box and secure it with provided screws.
- 3) Connect the low voltage thermostat to the control terminals of the relay.
- 4) Make the connection of the relay according to the wiring diagram on the access control box cover.
- 5) Secure access control box cover and reconnect power supply.
- 6) Check relay by temporarily setting the thermostat at maximum temperature and then, at the minimum. Adjust the thermostat at the desired set point.

INS224-200705-01

